

MEMORANDUM FOR: Assistant Deputy Director (Administration)

FROM : Acting Chief, Logistics

SUBJECT : Water Supply, [REDACTED]

25X1A6a

REFERENCE : Memorandum to Emergency Planning Officer,
CIA, dated 30 March 1953.

1. A survey [REDACTED] was made on 29 April 1953 with reference to providing a sufficient water supply for domestic consumption and fire protection in the event of low city water pressure or disruption of the city water supply system.

25X1A6a

2. The survey substantiates the statements made in the reference memorandum and the following proposals are suggested:

- a. Provide a 200,000 gallon steel storage tank on the high ground near the office building. Tank to provide for "complete outage" of the city water system for a minimum period of five (5) days.
Estimated Cost \$20,000.00
- b. Provide booster pumps to take supply from either (or both) the city system or the storage tank, to maintain a minimum water pressure of 40 lbs.
Estimated Cost \$ 1,800.00
- c. Provide emergency fire hose stations at strategic locations in each building, generally two stations on each floor.
Estimated Cost \$ 2,000.00

Total Estimate \$23,800.00

3. The use of the fish pond mentioned in the reference memorandum for supplementary fire protection is not recommended.

- a. The drainage area surrounding the pond is not considered sufficient to maintain the required water level.

- 2 -

- b. Maintaining pond storage capacity from the city water supply is not justified if the steel storage tank is provided.

4. [REDACTED] advises that in discussing this problem with the ADD/A, it was indicated that if the project was approved, fiscal year 1953 funds would be allocated.

25X1A6a

5. It is recommended:

- a. That action as proposed in paragraph 2 above be approved.
- b. That funds in accordance with the estimate of \$23,800.00 be approved in order that this Office may prepare the necessary drawings, contract documents, and award contract using fiscal year 1953 funds.

[REDACTED] 25X1A9a